

Acoustic data



Standard: BS EN 13141-7:2010

Ventilation for buildings. Performance testing of components/products for residential ventilation. Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings

Product

**HRV1.25 Qplus Eco**

Speed		'A' Weighted Sound Power Levels dB re. 1pW								Overall L <sub>W</sub>	Overall L <sub>WA</sub>	Casing Breakout dBA @ 3m
		Frequency Hz										
		63	125	250	500	1k	2k	4k	8k			
11l/s @ 3Pa (25%)	Induct Outlet	31	39	38	46	35	22	20	24	60	47	17
	Induct Inlet	33	33	28	25	20	15	19	24	60	37	
	Breakout	9	27	32	26	26	14	19	24	45	35	
20l/s @ 8Pa (40%)	Induct Outlet	37	47	47	50	50	39	30	25	67	55	19
	Induct Inlet	29	40	34	35	34	22	20	24	59	43	
	Breakout	13	28	32	29	29	18	20	24	47	36	
22l/s @ 10Pa (45%)	Induct Outlet	36	49	50	52	55	42	34	27	68	58	20
	Induct Inlet	32	42	37	36	37	26	21	24	61	45	
	Breakout	16	29	31	32	32	21	20	24	48	38	
27l/s @ 13Pa (52%)	Induct Outlet	39	53	53	55	60	47	40	32	72	62	23
	Induct Inlet	33	46	40	39	42	30	24	24	64	49	
	Breakout	16	32	32	35	35	25	22	24	50	40	
29l/s @ 17Pa (58%)	Induct Outlet	41	54	56	57	60	50	43	36	73	64	25
	Induct Inlet	34	48	42	41	42	33	26	24	65	50	
	Breakout	15	33	33	37	38	28	22	24	51	42	
34l/s @ 23Pa (66%)	Induct Outlet	42	56	60	60	61	54	47	42	75	66	28
	Induct Inlet	37	50	45	44	46	37	30	25	68	53	
	Breakout	24	34	38	41	41	35	27	26	55	46	
43l/s @ 36Pa (80%)	Induct Outlet	46	58	65	65	67	60	53	49	79	71	32
	Induct Inlet	40	52	51	49	49	43	36	29	71	57	
	Breakout	32	35	42	45	44	41	32	28	60	50	
56l/s @ 50Pa (100%)	Induct Outlet	49	59	67	68	69	67	57	54	81	74	36
	Induct Inlet	46	54	53	53	51	52	41	34	74	60	
	Breakout	40	36	47	49	47	47	36	29	66	54	

Measurements taken at full speed with a resistance of 50Pa, then at the stated percentage speed settings of the unit and corresponding reduced pressure

Inlet and outlet levels are Induct (BS EN 13141-7 clause 6.4.2 requirement), casing breakout is hemispherical - for spherical subtract 3dB

Titon acoustic data is independently tested at Sound Research Laboratories

Data is specifically tested for the Eco unit (100% bypass) - non bypass variants with deeper heat exchangers will offer lower acoustic levels

Product

**HRV1.25 Qplus Eco**

		Sound Power Levels dB re. 1pW								Overall $L_W$	Overall $L_{WA}$	Overall dBA @ 3m Hemispherical	Overall dBA @ 3m Spherical
		Frequency Hz											
Speed		63	125	250	500	1k	2k	4k	8k				
11l/s @ 3Pa (25%)	Open Outlet	37	41	38	45	34	21	19	25	47	43	25	22
	Open Inlet	39	35	28	24	19	14	18	25	41	29	11	8
	Breakout	35	43	41	29	26	13	18	25	45	35	17	14
20l/s @ 8Pa (40%)	Open Outlet	43	49	47	49	49	38	29	26	55	52	34	31
	Open Inlet	35	42	34	34	33	21	19	25	44	37	19	16
	Breakout	39	44	41	32	29	17	19	25	47	36	19	16
22l/s @ 10Pa (45%)	Open Outlet	42	51	50	51	54	41	33	28	58	55	37	34
	Open Inlet	38	44	37	35	36	25	20	25	46	39	21	18
	Breakout	42	45	40	35	32	20	19	25	48	38	20	17
27l/s @ 13Pa (52%)	Open Outlet	45	55	53	54	59	46	39	33	62	60	42	39
	Open Inlet	39	48	40	38	41	29	23	25	50	43	26	23
	Breakout	42	48	41	38	35	24	21	25	50	40	23	20
29l/s @ 17Pa (58%)	Open Outlet	47	56	56	56	59	49	42	37	63	61	43	40
	Open Inlet	40	50	42	40	41	32	25	25	51	44	26	23
	Breakout	41	49	42	40	38	27	21	25	51	42	25	22
34l/s @ 23Pa (66%)	Open Outlet	48	58	60	59	60	53	46	43	66	63	45	42
	Open Inlet	43	52	45	43	45	36	29	26	54	47	30	27
	Breakout	50	50	47	44	41	34	26	27	55	46	28	25
43l/s @ 36Pa (80%)	Open Outlet	52	60	65	64	66	59	52	50	70	68	51	48
	Open Inlet	46	54	51	48	48	42	35	30	58	52	34	31
	Breakout	58	51	51	48	44	40	31	29	60	50	32	29
56l/s @ 50Pa (100%)	Open Outlet	55	61	67	67	68	66	56	55	73	72	54	51
	Open Inlet	52	56	53	52	50	51	40	35	60	56	38	35
	Breakout	66	52	56	52	47	46	35	30	66	54	36	33

Measurements taken at full speed with a resistance of 50Pa, then at the stated percentage speed settings of the unit and corresponding reduced pressure  
 To enable simplified comparisons with other manufacturers data the above information is tested in accordance with BS EN 13141-7, the end reflection as defined in EN ISO 5135  
 for a 125mm (204x60mm) duct mounted flush with the wall, has been removed to provide an open outlet/open inlet sound power measurement (see page 1 of 2 for original data)  
 Figures shown are not 'A' weighted (other than the overall  $L_{WA}$ /dBA columns)

Titon acoustic data is independently tested at Sound Research Laboratories

Data is specifically tested for the Eco unit (100% bypass) - non bypass variants with deeper heat exchangers will offer lower acoustic levels

## Acoustic Testing – Powered products

Acoustic testing of Titon mechanical ventilation products is measured in accordance with the following standards:-

**CME – BS EN 13141-6** – “Ventilation for buildings. Performance testing of components/products for residential ventilation. Exhaust ventilation system packages used in a single dwelling”

**MVHR – BS EN 13141-7** – “Ventilation for buildings. Performance testing of components/products for residential ventilation. Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings”

The results (1<sup>st</sup> page) are presented in the following format which provides details of the acoustic performance of the unit at each of the standard speed settings.

The ‘A’ Weighted Sound Power Level in dB is an “in-duct” measurement for the Outlet (supply) and Inlet (extract) and are given across the frequency range from 63Hz to 8kHz.

The overall level is the logarithmic addition of the frequency bands to give a single figure, this is provided with and without ‘A’ weighting

The casing breakout is a sound pressure level at a distance of 3 metres, this figure is the lowest quoted and is usually stated in catalogue details. It is calculated from the Overall L<sub>WA</sub> (sound power level) with a reduction to convert to the sound pressure at 3 metres (see page 7).

### Acoustic data



Standard: BS EN 13141-7:2010

Ventilation for buildings. Performance testing of components/products for residential ventilation. Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings

Product: **HRV2.85 Plus Eco**

Speed		'A' Weighted Sound Power Levels dB re. 1pW								Overall L <sub>W</sub>	Overall L <sub>WA</sub>	Casing Breakout dBA @ 3m
		Frequency Hz										
		63	125	250	500	1k	2k	4k	8k			
15l/s @ 1Pa (18%)	Induct Outlet	28	35	32	32	27	17	19	23	56	39	11
	Induct Inlet	28	28	25	21	15	15	14	23	54	33	
	Breakout	4	16	17	25	21	17	18	21	36	29	
29l/s @ 7Pa (30%)	Induct Outlet	34	46	41	45	41	33	24	23	64	50	14
	Induct Inlet	30	34	33	30	24	20	19	23	57	39	
	Breakout	7	22	21	27	25	19	19	21	40	31	
45l/s @ 18Pa (41%)	Induct Outlet	37	52	48	54	54	44	36	30	70	59	19
	Induct Inlet	33	41	40	37	35	29	22	23	61	45	
	Breakout	9	28	26	31	31	24	21	21	45	36	
61l/s @ 40Pa (53%)	Induct Outlet	44	57	53	59	61	51	45	41	75	64	24
	Induct Inlet	38	46	45	43	43	36	28	24	66	51	
	Breakout	14	33	32	36	37	30	26	21	51	41	
75l/s @ 65Pa (65%)	Induct Outlet	48	59	58	63	65	57	50	47	79	69	27
	Induct Inlet	41	49	48	47	48	41	33	27	70	55	
	Breakout	16	36	35	40	40	34	31	22	54	45	
88l/s @ 83Pa (76.5%)	Induct Outlet	51	62	62	65	69	62	55	52	82	72	33
	Induct Inlet	46	52	52	50	51	45	37	31	74	58	
	Breakout	19	40	40	48	44	40	37	25	59	51	
93l/s @ 100Pa (100%)	Induct Outlet	51	64	63	66	70	63	55	53	82	73	34
	Induct Inlet	46	53	53	51	52	47	39	33	74	59	
	Breakout	24	41	42	48	46	42	39	27	59	52	

Measurements taken at full speed with a resistance of 100Pa, then at the stated percentage speed settings of the unit and corresponding reduced pressure

Inlet and outlet levels are Induct (BS EN 13141-7 clause 6.4.2 requirement), casing breakout is hemispherical - for spherical subtract 3dB

Titon acoustic data is independently tested at Sound Research Laboratories

Data is specifically tested for the Eco unit (100% bypass) - non bypass variants with deeper heat exchangers will offer lower acoustic levels

MD0268f-03, SRL report 23276/T01, 07/10/16

A second page of the same results is also provided with the same information presented in an alternative format, this is provided to enable simplified direct comparisons to some competitor units where “open outlet” or “open inlet” data is being quoted (outside the requirements of 13141-7).

The overall level is the logarithmic addition of the frequency bands to give a single figure, this is provided with and without ‘A’ weighting.

The open outlet and open inlet figures are calculated from the induct levels given on page 1 by deducting the end reflection (as defined in EN ISO 5135 for a duct flush with the wall).

The overall levels have also been given as a sound power ( $L_w$ ) and sound pressure at a distance of 3 meters, both hemispherical and spherical. The only A weighted data is the overall “dBA” at 3 metres.

Acoustic data

Product **HRV2.85 Plus Eco**

Speed		Sound Power Levels dB re. 1pW								Overall $L_w$	Overall dBA @ 3m Hemispherical	Overall dBA @ 3m Spherical
		Frequency Hz										
		63	125	250	500	1k	2k	4k	8k			
15l/s @ 1Pa (18%)	Open Outlet	36	38	34	32	26	16	18	24	42	21	8
	Open Inlet	36	31	27	21	14	14	18	24	38	16	7
	Breakout	30	32	26	28	21	16	17	22	36	11	8
29l/s @ 7Pa (30%)	Open Outlet	42	49	43	45	40	32	23	24	52	32	29
	Open Inlet	38	37	35	30	23	19	18	24	42	21	18
	Breakout	33	38	30	30	25	18	18	22	40	14	11
45l/s @ 18Pa (41%)	Open Outlet	45	55	50	54	53	43	35	31	60	41	38
	Open Inlet	41	44	42	37	34	28	21	24	48	28	25
	Breakout	35	44	35	34	31	23	20	22	45	19	16
61l/s @ 40Pa (53%)	Open Outlet	52	60	55	59	60	50	44	42	65	47	44
	Open Inlet	46	49	47	43	42	35	27	25	53	33	30
	Breakout	40	49	41	39	37	29	25	22	51	24	21
75l/s @ 65Pa (65%)	Open Outlet	56	62	60	63	64	56	49	48	69	51	48
	Open Inlet	49	52	50	47	47	40	32	28	57	37	34
	Breakout	42	52	44	43	40	33	30	23	54	27	24
88l/s @ 83Pa (76.5%)	Open Outlet	59	65	64	65	68	61	54	53	73	55	52
	Open Inlet	54	55	54	50	50	44	36	32	60	40	37
	Breakout	45	56	49	51	44	39	36	26	59	33	30
93l/s @ 100Pa (100%)	Open Outlet	59	67	65	66	69	62	54	54	73	55	52
	Open Inlet	54	56	55	51	51	46	38	34	61	41	38
	Breakout	50	57	51	51	46	41	38	28	59	34	31

Measurements taken at full speed with a resistance of 100Pa, then at the stated percentage speed settings of the unit and corresponding reduced pressure  
To enable simplified comparisons with other manufacturers data the above information is tested in accordance with BS EN 13141-7, the end reflection as defined in EN ISO 5135 for a 125mm (204x60mm) duct mounted flush with the wall, has been removed to provide an open outlet/open inlet sound power measurement (see page 1 of 2 for original data)

Figures shown are not 'A' weighted (other than the overall dBA columns)


Titon acoustic data is independently tested at Sound Research Laboratories

Data is specifically tested for the Eco unit (100% bypass) - non bypass variants with deeper heat exchangers will offer lower acoustic levels


MD0268f-03, SRL report 23276/T01, 07/10/16

## MVHR – Installation set up used during testing

Induct sound power level measurement – the unit is installed with the outlet (or inlet) connected to the measurement room and a pressure difference of 100Pa is set across the inlet to outlet connections whilst the unit is operated at full speed. The test is then repeated to measure the casing breakout. A number of reduced speed settings are also taken with the pressure difference reducing with the flow rate.




Casing breakout – the inlet and outlet ducts are connected to a separate room so the only noise measured is breakout from the casing.




The performance graph below shows the inlet acoustic levels starting at 100Pa and also 200Pa, the acoustic level is similar at the same speed setting with a reduction of 2 dB at the higher resistance.

Example sound data based on different system resistances




## CME – Installation set up used during testing

Inlet sound power levels – all 3 inlets from the CME are fitted with a standard duct set up (as BS EN 13141-6, one is connected to the measuring room and the inlet sound power level recorded. The three inlets connected with 90 degree bend, 0.5m duct and air terminal device  
 The single outlet connected with 0.5m duct, 45 degree bend 2m duct, and grille.  
 All duct work 204 x 60mm plastic.



Casing breakout – the inlet and outlet ducts are connected to a separate room so the only noise measured is breakout from the casing.





## Glossary

**Sound Power Level (SWL or  $L_{WA}$ )** – is a measurement of the actual sound level created at the source, it is not therefore affected by the environment in which the product is installed. This will always be the highest levels quoted as no reductions have been applied for either the environment or distance from the source. Actual installed levels will therefore be significantly lower than these figures but they are useful from which to base any system calculations.

**Sound Pressure Level (SPL or  $L_{pA}$ )** – this must be quoted at a given distance and is dependant on both the distance from the source and environment (a hard walled reflective surface will have a higher level than a soft furnished room which absorbs more sound). Titon levels are given at a distance of 3m (which is commonly quoted) and are free field, hemispherical radiation.

**Free field** – An environment in which there are no reflective surfaces (useful to describe the sound pressure levels for comparative purposes)

**Hemispherical radiation** – Sound radiates from a source in all directions, where the product is mounted on a wall or ceiling some sound is reflected from this mounting face. The casing sound pressure levels are based on hemispherical radiation which will be slightly higher than spherical radiation.

Calculation:

$$\text{SPL} = \text{SWL} - 20 \log r - 8 \text{ dB}, \quad \text{where } r = \text{distance from source}$$

Or, **SPL = SWL – 17.54 dB** (when  $r = 3\text{m}$ )

**Spherical radiation** –

Calculation:

$$\text{SPL} = \text{SWL} - 20 \log r - 11 \text{ dB}, \quad \text{where } r = \text{distance from source}$$

Or, **SPL = SWL – 20.54 dB** (when  $r = 3\text{m}$ ), i.e 3 dB quieter than hemispherical.

**'A'Weighting** – this is a correction to the frequency bands to replicate the sensitivity of the human ear to different frequencies. The weighting can be removed from the octave bands if required, the corrections are given in the table below.

Frequency Hz	63	125	250	500	1000	2000	4000	8000
'A' Weighting	-26	-16	-9	-3	0	1	1	-1

**Octave band** – sound is produced at various frequencies and is therefore measured across a range of frequency or Octave bands (as the above table). The figures can be combined to give an overall level using logarithmic addition.

**Induct levels** – a measurement of sound that is taken inside the duct of a ventilation system, this is likely to be a higher level than a non ducted or open inlet/open outlet measurement.

**Casing Breakout** – a measurement of the sound that breaks out of the casing of a unit, the sound from the inlet and outlets of the unit does not form part of this measurement.