



Description	4000GR	5000GR	7500GR	10000GR		
Slot Width (A)	13 or 16	13	16	13	16	16
Overall Slots (B)	330	420	350	600	500	660
Slot Length (C)	160	200	165	295	240	320
Bridge (D)	10	20	10	20	20	
Fixing Centres (E)	368.5	455.5	654.5			766.5

All dimensions in millimetres

This ventilator complies with Building Regulations Part 'J' for England & Wales.

This ventilator complies with BS 5440 Part 2 2000 "Installation and maintenance of flues and ventilation for gas appliances of rated input not exceeding 70kW net (1st, 2nd and 3rd family gases) Part 2: Specification for installation and maintenance of ventilation for gas appliances"

Air Vent Requirements for open flued gas appliances

Nett Input rating up to 7kW (25,000Btu/h)	No Requirement
From 7 - 15kW (51,000Btu/h)	4000mm <sup>2</sup> (4000GR)
From 15 - 22kW (75,000Btu/h)	7500mm <sup>2</sup> (7500GR)

For use with flueless appliances

5000mm<sup>2</sup> (5000GR)

**PLEASE REFER TO THE RELEVANT STANDARDS/REGULATIONS FOR MORE DETAILED INFORMATION.**  
**TITON CANNOT ADVISE ON CORRECT SIZING OR USAGE OF GAS REGS VENTILATORS, PLEASE REFER TO A QUALIFIED GAS PROFESSIONAL FOR ADVICE.**

### Gas Regulations Ventilator Fixing Details

**DANGER:** - Ensure window slot free area is at least equal to the ventilator free area.

1. Prepare slots and pre-drill  $\varnothing$  3mm fixing holes. Avoid glazing rebates and reinforcement.
2. Open screw covers and fix vents into position using screws provided. Close screw covers.

- Internal vent has warning label affixed.
- We recommend the use of a good quality silicone along the sealant groove.

### MARKETING DIVISION

International House, Peartree Road, Stanway, Colchester, Essex CO3 0JL

Tel: +44 (0) 1206 713800 Fax: +44 (0) 1206 543126 Web: www.titon.com